QUESTIONS AND ANSWERS

Reference is made to ITB UNOPS-ROADS-2016-W-018, Provision of rehabilitation works on bridge in Knjazevac municipality:

Question 1: Is it possible to perform works during the traffic?

Answer 1: Yes. The traffic should be enabled in one lane during the works.

Question 2: Position 6.4.5.9.1 Concrete prefabricated elements – which are the dimensions and what kind of concrete?

Answer 2: Detail was presented to the bidders during the site visit organized on 19 July 2016. Only hard copy of all details exist. Therefore the bidders should offer the classic prefabricated element dimensions 50x40xx30cm.

Question 3: The quantity for reinforcement in the BoQ is stated 5.611 kg, and in the total recapitulation there is 10.703kg - please provide specification for the rest of 5.092kg.

Answer 3: Specifications of the reinforcement are available in hard copy, and the bidder should offer according the attached BoQ.

Question 4: For the Position 6.4.5.9.2 the unit measure is m1. Is it actually m2?

Answer 4: Yes. The unit measure is m2

In Belgrade, 21 July 2016

UNOPS RSOC Office
Šumatovačka 59
11 000 Belgrade
Serbia
www.unops.org

Tel: +381 11 243 57 03
+381 11 244 56 87
Fax:: +381 11 245 07 72
e-mail: rspc.registry@unops.org

UNOPS is ISO 9001 certified